Dated: 24/09/2025

## FIRE SAFETY CERTIFICATE

No.

Certified that the Woodridge High School (name of the building or premises) at Gut No. 12, Kanchanwadi, Paithan Road, Chh. Sambhajinagar (address) comprised of- basement(s) and Ground + 3 floors (upper floors) occupied by Woodridge High School have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 20.02.2024 (date of inspection) in the presence of Mr. Deepak Kothari (name and addresses of the Manager/ Secretary or his representative) and that the building /premises is fit for occupancy up to classes XII (X/XII)With effect from 01/04/2025 for a period of 01 (One) year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1. Open Space All around the building is provided for the movement of fire tender and which will carry 25 tons weight capacity
- 2.Overtead Water tank 20000 Ltr 01 Nod & Main Fire Pump-10HO- 01 Nos.of suitable capacity for building is provided.
- 3. 01 Nos Fire service inlet 2 way incoming is provided.
- 4. 01 Nos Wet Riser all the building with fire Hose Pipe/ Branch-is provided.
- 5. 08 Nos Hose reel of 100 feet on all outlets ps provided.
- 6. Fire Extinguisher of ABC -06kg 30 Nos of Suitable Capacity/quantity is provided.

Issued on 03.03.2025 (date of issue) at Chh. Sambhajinagar (place) by

\*Strike out whichever is not applicable.

Signature with Seal:

Name

Designation

: Chief Fire Officer Fire

To
Woodridge High School
Gut No. 12, Kanchanwadi,
Paithan Road,
Chh. Sambhajinagar,

Name & Address of Dept./Office: Chh. Sambhajinagar